

FW: Auction Structures for Council

Chris Owen

BA COUNCIL@10:42 AM

John Zakian <john.zakian@minotnd.org>

John,

Here is the next batch of addresses for council approval to auction. Lead based paint testing next Wed and we'll advertise results accordingly, if needed.

Chris

From: Redding, Justin T. [mailto:reddingjt@cdmsmith.com]

Sent: Thursday, July 19, 2018 8:54 PM

To: Chris Owen <chris.owen@minotnd.org>

Cc: Hall, Wesley P. <hallwp@cdmsmith.com>

Subject: Auction Structures for Council

Hi Chris,

Here are the structures that were walked and ok to try to auction the structures depending on the environmental tests. We completed the asbestos inspections this week and below are the results.

6 5th St NE House – no asbestos found

615 2nd Ave NE Garage – no asbestos found

1100 6th Ave SW House – no asbestos found

1100 6th Ave SW Garage – asbestos present in window glaze

700 2nd Ave NE House – asbestos present in wall texture

700 2nd Ave NE Garage – no asbestos found

700 2nd Ave NE Shed – no asbestos found

807 2nd Ave NE House – no asbestos found

1025 6th Ave SW House – no asbestos found

1025 6th Ave SW Garage – no asbestos found

Let us know if you have any questions.

Thank You

Justin Redding

Construction Manager

CDM Smith - Minot Disaster Recovery Services

1600 2nd Ave SW, Suite 27

Minot, ND 58701

Office: 701-837-5813

reddingjt@cdmsmith.com

cdmsmith.com

<https://outlook.office.com/owa/?realm=minotnd.org&exsvurl=1&ll-cc=1033&modurl=0>