

City of Minot
 Inspections Department
 1025 31st St SE
 P.O. Box 5006
 Minot, ND 58702-5006

Office
 Fax
 Internet
 Inspection Request

(701) 857-4102
 (701) 857-4130
 www.minotnd.org
 (701) 857-4102



Inspection Checklist

2015 ICC International Building Codes: IBC; IMC; IFGC; IFC; IECC: 2017 NEC; 2009 UPC; 2009 ANSI A117; 2013 NFPA 13
 Effective January 1, 2019

Date: MAY 16 2019 @ 2:30 PM Business Name: EVA LUCKE (ROBERT MARTIN 852-4837) Initial Inspection

Lot Number / Address: 2112 N BROADWAY Follow-up Inspection

Inspector: Michael J Murphy
 THE CONTENT OF THIS DOCUMENT IS NOT ALL INCLUSIVE

ID No.	Inspection Category and On Site Conditions	Pass	Shall Correct	N/A	Comment
1. BUILDING					
1.1	metal				
1.2					
1.3					
2. EXTERIOR					
2.1	metal				
3. INTERIOR					
3.1	Insulated - spray on metal				
3.2					
3.3					
4. PLUMBING					
4.1					
4.2					
5. MECHANICAL					
5.1					
5.2					
6. LIFE SAFETY					
6.1	No Hand rail on Stairs				
6.2	Low handrail on Stairs app 5'				
6.3	(Guard rail openings too wide				
6.4	(max 4")				
6.5					
7.1 ADDITIONAL COMMENTS (use additional pages if necessary)					
58x16 STORE & office Hanger 78' X 58					
200 Amp conduit					