



Notes:

1. Pumper connection shall face the street.
2. Hydrant shall be 9'-0" bury.
3. Encase hydrant barrel in 8 mil poly.
4. Gate valve box per separate standard detail.

M:\STANDARD SPECS & DETAILS\2021\Detail\WAT-2 HYDRANT DETAIL WITH VERTICAL BEND.dwg

City Plate No.: WAT-2
Last Revision: 12/18/2020
Section: 2100

**STANDARD DETAILS
HYDRANT
WITH VERTICAL BEND**

